

1" CONDUIT. ROUTE TO VOICE/DATA PATHWAY (J-HOOKS OR CABLE TRAY) AND TERMINATE WITH BUSHING.

4" SQUARE JUNCTION BOX MOUNTED ABOVE ACCESSIBLE CEILING. IN AREAS WITHOUT ACCESSIBLE CEILING PROVIDE A PLASTER RING (HORIZONTAL) AND STAINLESS STEEL COVERPLATE. JUNCTION BOX SHALL BE INSTALLED ON UNSECURE SIDE OF DOOR.

WHERE EXIT SIGNS ARE REQUIRED, COORDINATE LOCATION OF EXIT SIGN WITH REQUEST—TO—EXIT DEVICE.

1/2" CONDUIT STUBBED INTO DOOR FRAME FOR DOOR POSITION SWITCH.

- 1" CONDUIT CONCEALED IN WALL

4" SQUARE JUNCTION BOX WITH 1/2" CONDUIT AND SINGLE GANG PLASTER RING (HORIZONTAL) FOR REQUEST TO EXIT DETECTOR. CENTERLINE SHALL BE AT 4" ABOVE TOP OF DOOR FRAME ON UNSECURE SIDE OF DOOR.

WHERE AN ELECTRONIC LOCKSET OR EXIT DEVICE IS SPECIFIED THE DOOR SHALL BE DRILLED TO PROVIDE A PATHWAY FOR THE WIRE. COORDINATE WITH DOOR HARDWARE SUPPLIER.

4" SQUARE JUNCTION BOX WITH SINGLE GANG PLASTER RING (VERTICAL) FOR CARD READER. CENTERLINE SHALL BE AT 42" ABOVE FINISHED FLOOR ON SECURE SIDE OF DOOR.

3/4" CONDUIT STUBBED INTO DOOR FRAME FOR ELECTRONIC STRIKE.

3/4" CONDUIT STUBBED INTO DOOR FRAME FOR ELECTRIC POWER TRANSFER. VERIFY EXACT LOCATION WITH DOOR HARDWARE SUPPLIER.

ACCESS CONTROL ROUGH-IN

SCALE: NONE