



- APPROPRIATE SEALANT (E.G., POLYURETHANE)
- DRAWBAND
- SHEET METAL RAIN COLLAR OVERLAPPING FLASHING COLLAR BY 3" TO 4"
- 1/4" MINIMUM CLEARANCE TO RAIN COLLAR
- MULTIPLE-PLY MODIFIED BITUMEN ROOF MEMBRANE
- SHEET METAL FLASHING COLLAR MINIMUM OF 8" ABOVE ROOFING
- MODIFIED BITUMEN MEMBRANE STRIPPING PLY
- 1/4" MINIMUM CLEARANCE BETWEEN FLASHING COLLAR AND SUPPORT
- COMPATIBLE ROOF CEMENT OR COMPATIBLE SEALANT AT PENETRATION TO MEMBRANE JUNCTURE
- 4" MINIMUM FLANGE SET IN COMPATIBLE ROOF CEMENT OVER FIELD PLYS PRIME FLANGE BEFORE STRIPPING (FOR ROOF SYSTEMS WITH FACTORY APPLIED GRANULE SURFACING, THE FLASHING COLLAR FLANGE AND MULTI-PLY MEMBRANE STRIPPING CAN BE APPLIED BETWEEN THE BASE PLY AND GRANULE-SURFACED SHEET)
- COVERBOARD INSULATION
- THERMAL INSULATION
- ROOF DECK
- FILL GAPS WITH INSULATION BOARD TO PROVIDE EVEN SUBSTRATE

EQUIPMENT SUPPORT STAND AND TYPICAL RAIN COLLAR PENETRATION DETAIL

SCALE: NTS